

VALVES REQUIRED ON BOTH SIDES OF THE WATER METER FOR METER SIZES 2" AND GREATER

PROPERTY OWNER INSTALLED VALVE

WATER METER BOX

VALVE

WATER SERVICE LINE

DUCTILE IRON OR COPPER TO METER

GATE VALVE REQUIRED ON SERVICE 2" OR GREATER

DUCTILE IRON FIRE LINE

GATE VALVE

WATER MAIN

VAULT FOR REDUCED PRESSURE BACKFLOW DEVICE OR DOUBLE CHECK VALVE (PRIVATE)

REVISIONS:
11/30/2010
3/09/2011

VAULT AND WATER SERVICE

SCALE:	N.T.S
DATE:	May 2007
APPROVED BY:	D. Danicic
STANDARD DRAWING	317