
EXHAUST (10' FROM OPENINGS INTO PASSIVE RADON CONTROL SYSTEM IN CRAWL SPACE FOR NEW CONDITIONED SPACES OF BUILDING) CONSTRUCITON. 12" MIN. ABOVE ROOF NOTES INSTALL A LENGTH OF 4" DIAMETER PERFORATED DRAIN TILE HORIZONTALLY 1. BENEATH THE SHEETING AND CONNECT TO THE "T" FITTING WITH THE VERTICAL STANDPIPE THROUGH THE SOIL-GAS-RETARDER MEMBRANE. THIS HORIZONTAL PIPE SHOULD NORMALLY BE PLACED PARALLEL TO THE LONG DIMENSION OF THE HOUSE AND SHOULD EXTEND NO CLOSER THAN 6 FEET TO THE FOUNDATION WALL. FLASHING VENTILATE CRAWLSPACES IN CONFORMANCE WITH LOCAL CODES: VENTS 2. SHALL BE OPEN TO THE EXTERIOR AND BE OF NONCLOSEABLE DESIGN. RAFTER **ROOF SPACE** ATTIC JOIST LIVING AREA SUPPORT JOIST **STRAPPING** 3"-4" DIA. VENT PIPE CRAWL SPACE: NOTE 2 (PVC OR EQUIVALENT) SEAL MEMBRANE AROUND SOIL-GAS-RETARDER MEMBRANE SEALED AGAINST PIPE PENETRATION GRADE WALL AND AROUND PENETRATIONS (MIN. 6-ML ADJOINING SHEETS OF MEMBRANE POLYETHYLENE SHEETING OR EQUIVALENT) LEVEL OVERLAPPED AND SEALED PERFORATED DRAIN TILE: NOTE 1 **PVC T-FITING** (OR EQUIVALENT) TO SUPPORT VENT PIPE



PERMIT #:\_