



1. COAT ALL GALVANIZED PIPE OR EXPOSED STEEL WITH PROTECTIVE COATING CONFORMING TO AWWA C 203
2. RESTRAIN TYTON JOINT PLUG TO PIPE
3. THIS STANDARD APPLICABLE FOR PIPE SIZES THROUGH 8"
4. VALVE OPERATING NUT EXTENSION SHALL BE USED IF OPERATING NUT IS GREATER THAN 3' DEPTH FROM FINISH GRADE.

REVISIONS:
3/15/2010

BLOW-OFF ASSEMBLY

SCALE:	N.T.S
DATE:	May 2007
APPROVED BY:	D. Danicic
STANDARD DRAWING	311