



1. HYDRANT TO HAVE TWO 2 1/2" AND ONE 4 1/2" OPENING (ANSI STD.).
2. 6" MINIMUM PIPE SIZE SUPPLYING HYDRANT.
3. USE 6" MJ HOLDING SPOOL PER DWG. 305
4. ADJUSTING SPOOL NOT TO BE USED ON NEW CONSTRUCTION.
5. HYDRANTS SHALL BE INSTALLED UPON A PRE-FORMED CONCRETE BLOCK WITH CLEAN 2" DRAIN ROCK PLACED A MINIMUM OF 6" ABOVE DRAIN HOLES.
6. 30# TAR PAPER SHALL BE PLACED ON TOP OF THE DRAIN ROCK TO SEPARATE ROCK FROM NATIVE MATERIAL.
7. ENTIRE FIRE HYDRANT SPOOL SHALL BE RESTRAINED WITH FIELD-LOK GASKETS/MEGALUGS
8. VALVE OPERATING NUT EXTENSION SHALL BE USED IF OPERATING NUT IS GREATER THAN 3' DEPTH FROM FINISH GRADE.