



EXHIBIT D

Water Service Memo



DAVID EVANS
AND ASSOCIATES INC.

MEMORANDUM

DATE: May 18, 2018

TO: Dan Danicic
Del Boca Vista – Riverland, LLC
500 E. Hancock Street
Newberg, OR 97132

FROM: Brady Berry, PE

SUBJECT: Riverrun Subdivision – Water Service

PROJECT: DBVC0000-0002
Riverrun Subdivision

CC: File

The purpose of this memorandum is to document the preliminary design for water service to the Riverrun subdivision in Newberg Oregon. The proposed development design will meet the minimum pressure requirements of 40 PSI measured at each lot service meter and 20 PSI residual with a 1,000 GPM flow-rate for each proposed hydrant.

The preliminary design calculations are based on flow tests from the existing hydrant at 1210 S College Street near the project water main connection point. The residual pressures at proposed hydrants, which provided the greatest effective length from the proposed water main connection point, was determined for both Phase 1 and Phase 2 project areas. Preliminary calculations for the residual pressures at these locations are attached.

Attachments/Enclosures: EX020 Fire Service Exhibit; Water Service Flow Calculations; Existing Fire Hydrant Flow Test

File Path: P:\D\DBVC00000002\0600INFO\EC\02_Water System Design\Water Memo.docx

Water Service Flow Calculations

Riverrun Subdivision

Design By: NJRU

Date: 5/17/18

Check By: BLBE

Equations:

Equivalent Fitting Length (ft) = Σ [Equivalent Fitting Length x Number of Fittings]

Effective Length, L (ft) = Pipe Length (ft) + Equivalent Fitting Length (ft)

Velocity, v (fps) = Q (gpm) x 0.00223 (cfs/gpm) / Cross-Sectional Pipe Area (ft)

Head Loss, h (ft) = $10.44 \times L \text{ (ft)} \times Q \text{ (gpm)}^{1.85} / [C^{1.85} \times d \text{ (in)}^{4.8655}]$

Final Residual Pressure, P_f (psi) = $[62.4 / 144] \times [[P_i \text{ (psi)} \times 144 / 62.4] - [v \text{ (fps)}^2 / [2 \times 32.2]] - h \text{ (ft)}]$

From Node	To Node	Pipe Length (ft)	Eq. Fitting Length (ft)	Effective Length, L (ft)	Pipe Diameter, d (in)	Flow Rate, Q (gpm)	Velocity, v (fps)	Roughness Coefficient, C	Head Loss, h (ft)	Initial Static Pressure, P _i (psi)	Final Residual Pressure, P _f (psi)
N1	N2	2930	111.4	3041.4	8	1000	6.39	100	90.74	100	60
N1	N3	2450	217.4	2667.4	8	1000	6.39	100	79.58	100	65



WYATT

FIRE PROTECTION, INC.

9095 S.W. Burnham
Tigard, OR 97223

Fire Hydrant Fire Flow

PROJECT	RIVER RUN PROJECT
ADDRESS	
CROSS STREET	
FLOW	
HYDRANT LOCATION	1210 S. COLLEGE ST.
STATIC	100
PITOT RESIDUAL	76
GPM	1475
GPM AT 20 PSI	3489, 1 – 2.5 PORT FLOWED <i>calculated per NFPA 291</i>
DATED	02.06.18 12:50 pm
MONITOR	
HYDRANT LOCATION	150' EAST OF FLOW HYDRANT
STATIC	100
RESIDUAL	76
DATED	02.06.18 12:50 PM
WITNESS	
WITNESSED BY	
TITLE	
ORGANIZATION	NEWBERG PUBLIC WORKS
SIGNATURE	
PERFORMED BY	JACK GARDNER