

FIRE FLOW

SITE: Haworth and N Springbrook Rd

Newberg, Oregon

November 8, 2022 @ 09:30

Whitnessed by Vance Barton, City of Newberg

FLOW RESULTS ARE AS FOLLOWS:

91psi Static

90psi Residual

85psi Pitot

1547 GPM

2.5" Nozzle I.D.

0.90 Nozzle Coefficient

